

NEW YORK STATE BOARD ON ELECTRIC
GENERATION SITING AND THE ENVIRONMENT

CASE 14-F-0490 - Application of Cassadaga Wind LLC for a
Certificate of Environmental Compatibility and
Public Need Pursuant to Article 10 to Construct
a Wind Energy Project.

ERRATA NOTICE

(Issued June 21, 2018)

The Order and Certificate of Environmental
Compatibility and Public Need with Conditions (Order), issued on
January 17, 2018 in this proceeding, as amended by the Order on
Rehearing issued on May 15, 2018, contains non-substantive
cross-referencing errors in the Certificate Conditions, which
are set forth in Appendix A to the Order. Appendix A is revised
as follows:

1. Condition 70(d), page 28, requires revised sound modeling to be performed by the Certificate Holder to demonstrate that the project is modeled to meet the regulatory limits set forth in Conditions 78(a), 78(b), and 78(e). The applicable regulatory limits for sound are set forth in Conditions 80(a), 80(b), and 80(f). Therefore, Condition 70(d) is hereby revised to cross-reference "Conditions 80(a), 80(b), and 80(f)" instead of "Conditions 78(a), 78(b), and 78(e)."
2. Condition 71(a), page 28, refers to Sound Testing Compliance and Noise Complaint Protocol and compliance with "the limits imposed by the Siting Board in these Certificate Condition." The reference is to multiple Conditions. Therefore, Condition 71(a) is hereby revised to "Certificate Conditions" instead of Certificate Condition."

3. Condition 72(b), page 30, requires a Sound Compliance Test to be submitted to the Siting Board by the Certificate Holder, subject to the same requirements as those set forth in "sub-condition 73(a)." The applicable requirements are in sub-condition 72(a). Therefore, Condition 72(b) is hereby revised to cross-reference "sub-condition 72(a)" instead of "sub-condition 73(a)."
4. Condition 80(c), page 35, requires the Certificate Holder to comply with noise limits for audible prominent tones. If audible prominent tones occur, the Certificate Holder is required to increase by 5 dBA the broadband overall noise level for evaluating compliance with the requirements of "sub-condition 70(a)." The applicable maximum noise limits and compliance requirements are set forth in sub-condition 80(a). Therefore, Condition 80(c) is hereby revised to cross-reference "sub-condition 80(a)" instead of "sub-condition 70(a)."
5. Condition 80(f), page 36, requires the Certificate Holder to comply with a noise limit of 40 dBA L_{eq} (1 hour) subject to the tonal penalties in "sub-condition 70(b)." The tonal penalties are set forth in Condition 80(c). Therefore, Condition 80(f) is hereby revised to cross-reference "sub-condition 80(c)" instead of "sub-condition 70(b)."

(SIGNED)

KATHLEEN H. BURGESS
Secretary